

Facility Summary in BEAVERHEAD County in the City of DELL

Location: DELL CENTER LLC
24 MAIN ST PO BOX 240036
DELL, MT 59724 BEAVERHEAD

Sys Fac ID: 01-01523

Last Inspected On: 10/8/2014

Operating Permit Renewal Date: 2/7/2018

Contact: (406) 276-3332

Owners/Operators: Dell Center LLC, Owner (406)-276-3332 ELLEN BURDICK
PO BOX 240064
DELL MT 59724-0064

Jeanne Schnitzler, UST Class A Operator

Joel Schnitizer, UST Class B Operator

Jeanne Schnitzler, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	10	10/6/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5045		9/24/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
5	10	10/6/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5046		9/24/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
6	10	10/6/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5047		9/24/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
7	10	10/6/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5048		9/24/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DELL

Location: DELL AIRPORT CANYON RANCH
DELL AIRPORT
DELL, MT 59724 BEAVERHEAD

Sys Fac ID: 01-09843

Last Inspected On: 10/30/2015

Operating Permit Renewal Date:

Contact:

Owners/Operators: Montana Department of Transportation, Owner (406)-444-6163 2701 PROSPECT
PO BOX 201001
HELENA MT 59620

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	26	6/13/1989	Cathodically Protected Steel	No Piping	High Level Alarm
516			Double-Walled	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Galvanic
Jet Fuel		10/28/2015	Manual Interstitial Monitor	Deferred	
10,000					

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: THE MINI INC
410 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 01-01215
Last Inspected On: 10/9/2015
Operating Permit Renewal Date: 10/13/2018

Contact: Jeff DuBose, (406) 683-6168

Owners/Operators: The Mini Inc, Owner (406)-683-6168 410 N MONTANA ST
DILLON MT 59725-3313

Mandy Cerino, UST Class A Operator
Jeffrey DuBose, UST Class A Operator
Lori DuBose, UST Class A Operator
Cathie Wasser, UST Class A Operator
JimiKaye Balsley, UST Class B Operator
Jill Bertrand, UST Class B Operator
Brian Boyd, UST Class B Operator
Mandy Cerino, UST Class B Operator
Rachel Cherry, UST Class B Operator
Katie Corrigan, UST Class B Operator
Jeffrey DuBose, UST Class B Operator
Lori DuBose, UST Class B Operator
Lynette Goodale, UST Class B Operator
Vonnica Knapp, UST Class B Operator
Shadeen Novich, UST Class B Operator
Margaret Smith, UST Class B Operator
Cathie Wasser, UST Class B Operator
Lydia Wellborn, UST Class B Operator
Dennis A Franks, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	17	5/6/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3088		10/9/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: THE MINI INC
410 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 01-01215

Last Inspected On: 10/9/2015

Operating Permit Renewal Date: 10/13/2018

Contact: Jeff DuBose, (406) 683-6168

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	17	5/6/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3089		10/9/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			Gilbarco EMC Basic , Gilbarco		
6	17	5/6/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3090		10/9/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: DIETRICH'S COLLEGE EXXON UST
636 S ATLANTIC ST
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 01-05401

Last Inspected On: 11/14/2015

Operating Permit Renewal Date:

Contact: Timothy Dietrich, (406) 683-0070

Owners/Operators: Timothy Dietrich, Owner (406)-683-0070 636 S ATLANTIC ST
DILLON MT 59725-2725

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	21	7/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3227			None	None	Yes
Temporarily Out of Use		7/1/2004	Not Required	Safe Suction	Galvanic
Gasoline		11/14/2015	Tank Tightness Testing, Inventory Reconciliation	Deferred	
6,000					
2	21	7/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3226			None	None	Yes
Temporarily Out of Use		7/1/2004	Not Required	Safe Suction	Galvanic
Gasoline		11/14/2015	Tank Tightness Testing, Inventory Reconciliation	Deferred	
10,000					

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: COUNTY COURTHOUSE
2 S PACIFIC ST
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 01-05668

Last Inspected On: 7/2/2014

Operating Permit Renewal Date: 11/6/2017

Contact: Chris Kraft, (406) 683-2642

Owners/Operators: Beaverhead County Clerk, Owner (406)-683-5245 2 S PACIFIC ST
DILLON MT 59725-4000
Chris Kraft, UST Class A Operator
Chris Kraft, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	2/1/1993	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
421			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/2/2014	Automatic Tank Gauging 0.2	Deferred	
2,000		3/1/2008	TLS-250 , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: TOWN PUMP INC DILLON 1
101 E HELENA ST
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 01-08695

Last Inspected On: 2/4/2015

Operating Permit Renewal Date: 2/6/2018

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Town Pump Inc Butte, Owner

(406)-782-9121

PO BOX 6000

BUTTE MT 59702-6000

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	54	4/14/1961	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4794			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/12/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	30	1/1/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4795			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	30	1/1/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4796			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: TOWN PUMP INC DILLON 2
635 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 01-08696

Last Inspected On: 6/30/2015

Operating Permit Renewal Date: 10/14/2018

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Major Brands Distributing Imports Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	25	9/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2375		3/30/2015	None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	25	9/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2376		3/30/2015	None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
4	25	9/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2372		3/30/2015	None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	25	9/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2373		3/30/2015	None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: TOWN PUMP INC DILLON 2
635 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 01-08696
Last Inspected On: 6/30/2015
Operating Permit Renewal Date: 10/14/2018

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	25	9/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2374		3/30/2015	None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
7	16	5/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4541			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	14	8/20/2001	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4356		3/30/2015	Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
9	14	8/20/2001	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4357		3/30/2015	Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
5,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: ROCKY MOUNTAIN SUPPLY INC DILLON
700 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 01-10034

Last Inspected On: 11/2/2015

Operating Permit Renewal Date: 2/19/2019

Contact: Jason Rorabaugh, (406) 683-2308

Owners/Operators: Rocky Mountain Supply Inc, Owner (406)-388-4008 JASON RORABAUGH PETROLEUM MGR
PO BOX 129
BELGRADE MT 59714-3035

Jason Rorabaugh, UST Class A Operator
Tari Eaves, UST Class B Operator
Michael Holton, UST Class B Operator
Kevin Lathrop, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	35	1/12/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3900			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/22/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		1/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
2	35	1/12/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3901			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/22/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		1/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
3	35	1/12/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3902			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/22/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		1/27/2009	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: ROCKY MOUNTAIN SUPPLY INC DILLON
700 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 01-10034

Last Inspected On: 11/2/2015

Operating Permit Renewal Date: 2/19/2019

Contact: Jason Rorabaugh, (406) 683-2308

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	35	1/12/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3903			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/22/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		1/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
5	35	1/12/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3904			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/22/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		1/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
9	17	12/1/1998	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3905			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/25/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		6/22/2015	TLS-350/Gilbarco EMC , Veeder Root		
10	17	12/1/1998	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3906			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/25/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,100		6/22/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: ROCKY MOUNTAIN SUPPLY INC DILLON
700 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 01-10034

Last Inspected On: 11/2/2015

Operating Permit Renewal Date: 2/19/2019

Contact: Jason Rorabaugh, (406) 683-2308

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
11	17	12/1/1998	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3907			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/25/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
7,900		6/22/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: GATEWAY CANYON TRAVEL PLAZA
4055 REBICH LN
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 01-13101

Last Inspected On: 3/2/2015

Operating Permit Renewal Date: 3/3/2018

Contact: Dustin Clint, (443) 745-8081

Owners/Operators: Beseckers Excavation & Trucking, Owner (937)-459-9159 4055 REBICH LN
DILLON MT 59725

Patricia Besecker, UST Class A Operator
Casey Palmer, UST Class A Operator
Patricia Besecker, UST Class B Operator
Casey Palmer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	7/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4634			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	22	7/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4635			None	None	Yes
Currently in Use		7/1/2003	Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	22	7/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4636			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: GATEWAY CANYON TRAVEL PLAZA
4055 REBICH LN
DILLON, MT 59725 BEAVERHEAD
Contact: Dustin Clint, (443) 745-8081

Sys Fac ID: 01-13101
Last Inspected On: 3/2/2015
Operating Permit Renewal Date: 3/3/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	22	7/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4637			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
5	22	7/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4638			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: DILLON AIRPORT
2400 AIRPORT RD
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 56-13894

Last Inspected On: 1/9/2015

Operating Permit Renewal Date: 3/4/2018

Contact: Denise DeVino, (406) 683-5242

Owners/Operators: Beaverhead County Clerk, Owner (406)-683-5245 2 S PACIFIC ST
DILLON MT 59725-4000
Chris Kraft, UST Class A Operator
Chris Kraft, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	33	4/1/1982	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3995			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Jet Fuel		1/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		4/9/2014	Gilbarco EMC Basic , Gilbarco		
2	33	4/1/1982	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3996			Lined Interior/Impressed Current	None	Yes
Currently in Use		3/1/2009	Mechanical Line Leak Detector	Pressurized	Impressed Current
Aviation Gas		1/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		4/9/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: SAFEWAY 1581 DILLON
570 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Sys Fac ID: 56-13989

Last Inspected On: 6/13/2013

Operating Permit Renewal Date: 11/5/2016

Contact: Shanna Sunderlin, (406) 596-0388

Owners/Operators: Safeway Stores Inc, Owner (425)-455-6545 1121 124TH AVE NE
BELLEVUE WA 98005-2101

Aaron Nelson, UST Class A Operator

Lynn Pehrson, UST Class A Operator

Shanna Sunderlin, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	15	10/9/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4222			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
20,000				Continuous Interstitial Monitor	
2	15	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4223			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000				Continuous Interstitial Monitor	
3	15	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4224			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000				Continuous Interstitial Monitor	

Facility Summary in BEAVERHEAD County in the City of JACKSON

Location: CIRCLE S RANCH
30300 HIGHWAY 278
JACKSON, MT 59736 BEAVERHEAD

Sys Fac ID: 01-07024

Last Inspected On: 3/13/2014

Operating Permit Renewal Date: 6/3/2017

Contact: Cindy Yorton, (406) 834-3450

Owners/Operators: Circle S of Montana, Owner (406)-834-3450 30300 HIGHWAY 278
JACKSON MT 59736-9700

Robert Bertch, UST Class A Operator
Cindy Yorton, UST Class A Operator
Robert Bertch, UST Class B Operator
Cindy Yorton, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	18	7/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4228			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1	Deferred	
1,000					
6	18	7/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4229			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1	Deferred	
1,000					

Facility Summary in BEAVERHEAD County in the City of LIMA

Location: RALPHS EXXON
114 SOUTH HARRISON
LIMA, MT 59739 BEAVERHEAD
Contact: Kevin Stosich, (406) 276-3431

Sys Fac ID: 01-00671
Last Inspected On: 8/9/2013
Operating Permit Renewal Date: 9/21/2016

Owners/Operators: Kevin Stosich, Owner (406)-276-3376 T & R ENTERPRISES INC
PO BOX 206
LIMA MT 59739-0206
Kevin Stosich, UST Class A Operator
Kevin Stosich, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	17	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2078		10/8/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000					
8	17	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2079		10/8/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000					

Facility Summary in BEAVERHEAD County in the City of LIMA

Location: LIMA SCHOOL DIST 12 INC
1 N HARRISON ST
LIMA, MT 59739 BEAVERHEAD

Sys Fac ID: 01-07158

Last Inspected On: 8/27/2014

Operating Permit Renewal Date: 1/17/2018

Contact: Tim Slater Jr, (406) 276-3571

Owners/Operators: School Dist 12 Lima, Owner

(406)-276-3571

PO BOX 186

LIMA MT 59739-0186

Walt Patterson, UST Class A Operator

Walt Patterson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	23	6/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1535			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		8/27/2014	Manual Interstitial Monitor	Continuous Interstitial Monitor	
10,000		7/9/2012	Other , Other		

Facility Summary in BEAVERHEAD County in the City of WISDOM

Location: BIG HOLE PETROLEUM INC
318 MT HIGHWAY 43 PO BOX 175
WISDOM, MT 59761 BEAVERHEAD
Contact: Ed Stede, (406) 689-3225

Sys Fac ID: 01-02173
Last Inspected On: 5/1/2014
Operating Permit Renewal Date: 7/30/2017

Owners/Operators: Edward Stede, Owner (406)-689-3225 PO BOX 175
WISDOM MT 59761-0175
Edward Stede, UST Class A Operator
Edward Stede, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	30	3/10/1985	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3323			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		5/1/2014	Stat. Inventory Reconciliation	Deferred	
2,000		5/3/2005			
2	30	3/10/1985	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3324			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		5/1/2014	Stat. Inventory Reconciliation	Deferred	
1,000		5/3/2005			

Facility Summary in BEAVERHEAD County in the City of WISE RIVER

Location: WISE RIVER STORE
65221 HIGHWAY 43
WISE RIVER, MT 59762 BEAVERHEAD

Contact: Connie Holland, (406) 832-3271

Sys Fac ID: 01-02080
Last Inspected On: 5/21/2013
Operating Permit Renewal Date: 10/13/2016

Owners/Operators: JimCon Inc, Owner (406)-832-3271 65221 HWY 43
Wise River Mercantile, Operator (406)-832-3271 WISE RIVER MT 59762
65221 HWY 43
WISE RIVER MT 59762
Connie Holland, UST Class A Operator
Dawna Wilkinson, UST Class A Operator
Connie Holland, UST Class B Operator
Laura Delaney, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	17	6/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1224			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
2,000					